


HAZLETON CITY AUTHORITY WATER DEPARTMENT 2019 CONSUMER CONFIDENCE REPORT



PWS ID PA 2408001

Este informe contiene informacion muy importante sobre su agua potable Traduzcalo o hable con alguien que lo entienda lien

PURPOSE:

To comply with State and EPA regulations, the Hazleton City Authority issues a report annually describing the quality of your drinking water. This year's report, issued in June of 2020, contains monitoring data from the 2019 calendar year. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect your drinking water sources. This report provides an overview of last year's (2019) water quality. It includes details about where your water comes from and what it contains. If you have any questions about this report or your drinking water, please call us at (570) 454-2401. This report is available in English or Spanish on the HCA website: hcawater.org

BOARD OF DIRECTORS MESSAGE TO CUSTOMERS:

As a service to our customers, the Hazleton City Authority Board of Directors, are proud to distribute our annual Consumer Confidence Report. This year's report, issued in June of 2020, contains monitoring data from the 2019 calendar year.. This report is designed to inform you about your drinking water quality and services we deliver to you everyday. It is a continuous commitment, on our part, to provide the highest quality water and service that meets and exceeds all state and federal drinking water standards and regulations.

The Authority employs highly skilled personnel in the areas of water treatment, distribution, accounting and management. We pride ourselves in maintaining the highest level of integrity and superior service to our customers and our community.

If you have any questions about this report or concerning your water utility, please contact Randy Cahalan, Director of Operations, at the Hazleton City Authority -Water Department, 400 East Arthur Gardner Parkway, Hazleton, PA at (570) 454-2401. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held every Wednesday at 6:30 PM at the Hazleton City Authority Office.

THE SOURCE OF YOUR WATER:

Your drinking water originates from surface reservoirs, a well field, and the Lehigh River. The Humboldt and Mt. Pleasant Reservoirs and well field are located to the west of Hazleton. The Hudsondale and Dreck Creek Reservoirs are located to the east of Hazleton. Dreck Creek Reservoir is held full during dry periods by pumping water from the Lehigh River. The construction of the Lehigh River Pump Station in 1994 and recent dam rehabilitation projects, have allowed the Hazleton City Authority – Water Department to maintain uninterrupted service during drought periods in the last many years. The raw water sources provide high quality water that is delivered to the Hazleton City Authority Water Treatment Plant. At the treatment plant the raw water undergoes conventional water treatment processes prior to distribution to our customers.

CONTAMINANTS THAT MAY BE PRESENT IN SOURCE WATER INCLUDES:

The sources of drinking water both tap water and bottled water includes; rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land, or through the ground, it dissolves naturally occurring minerals, and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Water monitoring programs are designed to ensure that your water meets, or surpasses, all drinking water standards. Your water is monitored at the source and continues to be monitored through your local distribution system.

Substances that may be present in wells, lakes, reservoirs, and other untreated sources include:

- **Inorganic substances**, such as salts and metals that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operation, and wildlife.
- **Pesticides and herbicides**, which come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- **Organic Chemicals Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and may also come from gas stations, urban storm water runoff, and septic systems.

- **Radioactive Contaminants**, can be naturally occurring, or the result of oil and gas production or mining activities.

Cryptosporidium and Giardia (Measured on Raw Source Water Prior to Treatment) – Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR) Round 2 Cryptosporidium Monitoring Results

From October of 2016 through September of 2018, monthly cryptosporidium and giardia monitoring was conducted on the raw source water for the Hazleton City Authority Water Treatment Plant. The results of these samples demonstrate a mean Cryptosporidium Oocyst concentration of 0.016 oocysts/L, therefore, PA DEP classified Hazleton raw water sources as Bin 1. Bin 1 does not require additional Cryptosporidium treatment beyond existing Surface Water Treatment Rule Requirements.

Monitoring for cryptosporidium and giardia, microbial parasites commonly found in surface water, was conducted as part of the Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR). Current tests methods for cryptosporidium do not allow for the determination of whether the organisms detected were dead or if they are capable of causing disease. No individual point sources of cryptosporidium or giardia have been identified in the watershed. Typical sources would be fecal material from wildlife such as deer, other mammals, and warm blooded animals that are present in the watershed. Cryptosporidium and giardia must be ingested for it to cause disease, and may be transmitted through means other than drinking water. Symptoms of the infection include nausea, diarrhea, and abdominal cramps. These symptoms can also be the result of different food related organisms, flu or ingesting untreated water such as while swimming in lakes or reservoirs. Most healthy individuals are able to overcome the disease within a few weeks. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people living with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk. These people should seek advice from their health care provider. EPA/CDC guidelines on appropriate means to lesson the risk of infection by cryptosporidium or giardia and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

WATER QUALITY STATEMENT:

We are pleased to report that during the past year, the water delivered to your home or business complied with all state and federal drinking water requirements. For your information, we have compiled a list in the table below showing what substances were detected in your drinking water during 2019. The Pennsylvania DEP allows us to monitor for some contaminants less than once per year because the concentration of the contaminants does not change frequently. Some of our data, though representative, are more than one year old. Although all of the substances listed below are under the Maximum Contaminant levels (MCL) set by U.S. Environmental Protection Agency and the Pennsylvania DEP, we feel it is important that you know exactly what was detected and how much of each substance was present in the water.

Turbidity – A Measure of the Clarity of the Water at the Treatment Facility							
Plant	Year Sampled	Substance (Units)	MCL	Average Turbidity Leaving Plant	Range Low - High	Compliance Achieved	Typical Source
Turbidity - 99% of samples were below the TT value of 0.3	2019	Turbidity (NTU)	TT	0.03	0.01 – 0.40	Yes	Soil Runoff
All turbidity readings were below the treatment technique requirement of 0.3 NTU in 95% of all samples taken for compliance on a monthly basis and no single sample above 1.0 NTU.							

Regulated Substances (Measured on the Water Leaving the Treatment Facility)							
Substance (Units)	Year Sampled	MCL	MCLG/ MRDL	Average Amount Leaving Plant	Range Low - High	Compliance Achieved	Typical Source
Fluoride (ppm)	2019	2	2	0.47	0.12 – 1.6	Yes	Water Additive which promotes Strong Teeth
Total Chlorine Residual (ppm)	2019	N/A	4	1.14	1.00 – 2.80	Yes	Added as disinfectant to the treatment process
Nitrate (ppm)	2019	10	10	0.26	0 – 0.26	Yes	Erosion of natural deposits. Runoff from fertilizer use. Leaching from septic tanks.

Other Compounds (Measured in the Distribution System)

Substance (Units)	Year Sampled	MCL	MCLG	Results	Range Low - High	Compliance Achieved	Typical Source
Total Trihalomethanes (ppb)	2019	80	N/A	72.70	11.80 – 82.40	Yes	By-product of drinking Water chlorination
Haloacetic Acids (HAA5) (ppb)	2019	60	N/A	53.80	12.70 – 76.4	Yes	By-product of drinking Water chlorination

MCL (maximum contaminant level) applies and is based on a Locational Running Annual Average (LRAA) calculated quarterly. Under the Disinfection Byproducts Rule 2 (DBPR2) Sample sets are collected each quarter and the levels detected at each location are averaged for each location individually on a running annual basis. Compliance is based on the resulting running annual average at each individual location. The Result represents the highest LRAA for all locations during the year. The Range represents individual sample results for all locations from all four quarters.

Bacterial Test Results- Measured from Hazleton City Authority Distribution System

Substance (Units)	Year Sampled	MCL	MCLG	Highest Percentage Detected per Month	Compliance Achieved	Typical Source
Total Coliform (% of positive samples)	2019	No more that 5% of monthly samples can be positive	Zero Bacteria	0	Yes	Naturally present in the environment

Tap Water Samples: Lead and Copper Results

Substance (Units)	Year Sampled	Action Level	MCLG	Number of Samples	90 th Percentile	Number of Samples Above Action Level	Compliance Achieved	Typical Source
Lead (ppb)	2019	15	0	30	ND	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	2019	1.3	0	30	ND	0	Yes	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Total Organic Carbon Removal- Measured at Hazleton City Authority Treatment Plant

Substance (Units)	Year Sampled	Treatment Technique (TT)	TOC – less than 2.0 ppm on running average	Compliance Achieved	Typical Source
Total Organic Carbon (TOC)	2019	Meet EPA Removal Requirements	Yes	Yes	Naturally decaying vegetation

Adequate removal of TOC may be necessary to control the unwanted formation of chlorinated by-products. Naturally occurring organic matter present in the source water can react with the disinfectants used at the treatment facility to form these by-products.

HOW TO READ THIS TABLE:

Starting with a **Substance**, read across left to right. **Year Sampled** is usually in 2019 or prior year. **MCL** shows the highest level of substance (contaminant) allowed. **MCLG** is the goal level for that substance (goal may be set lower than what is allowed). **Highest Amount Detected** represents the measured amount (less is better). **Range** tells the highest

and lowest amounts measured. A **Yes** under **Compliance Achieved** means the amount of the substance met government requirements. **Typical Source** tells where the substance usually originates.

DEFINITIONS:

Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum contaminant level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible, using the best available treatment technology.

Maximum contaminant level goal (MCLG): The level of a contaminant in drinking water, below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contamination.

Nephelometric Turbidity Unit (NTU): Measurement of the clarity, or turbidity, of the water.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Parts Per Million (ppm): One part substance per million parts of water, or milligram per liter.

Parts Per Billion (ppb): One part substance per billion parts of water, or microgram per liter.

Not Applicable (N/A): Does not apply to this condition.

None Detected (ND): None of this substance was detected in samples collected.

TIER 3 PUBLIC NOTIFICATION – FAILURE TO MONITOR – PWS # 2408001

Monitoring requirements for Disinfection Bi-products, HAA5's, were not met for the second quarter (April – June) 2019.

Under the Pennsylvania Safe Drinking Water Regulations, Section 109.301(12)(i)(A) the Hazleton City Authority Hazleton Division is required to take at least four HAA5 samples per quarter. The Hazleton City Authority collected HAA5 samples during the second quarter of 2019 and samples were analyzed using an EPA approved laboratory and EPA approved method. The results received from these tests were well within PA DEP compliance limits for HAA5's. However, while the lab that ran the samples is certified to run HAA5 analyses in several other states, this lab is not certified in Pennsylvania. So PA DEP could not accept the sample results and a violation resulted. Even though this violation does not constitute a public health threat, you have the right to know what happened. All future HAA5 analyses will be performed by a laboratory certified in Pennsylvania.

If you have any questions regarding this matter, please contact Randy Cahalan, Director of Operations for the Hazleton City Authority at 400 E. Arthur Gardner Parkway, Hazleton PA 18201 or by telephone at 570-454-2401.

NOTICE OF UNREGULATED CONTAMINANT MONITORING COMPLETED – UCMR 4

The 1996 amendments to the Safe Drinking Water Act (SDWA) require that once every 5 years, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWS). The Unregulated Contaminant Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. These data serve as a primary source of occurrence and exposure information that the agency uses to develop regulatory decisions. If a PWS monitoring for UCMR4 finds contaminants in its drinking water, it must provide the information to its customers in this annual water quality report. Below is a table of the results of our UCMR4 monitoring in 2019 and 1st quarter of 2020. All other contaminants tested during UCMR4 were Not Detected.

Unregulated Contaminants detected during 2019 & 1st Qtr of 2020			
Unregulated Contaminants	Average Detection	Range of Detections	MCL
Raw Samples (untreated)			
Total Organic Carbon, ppb	912.5	0 - 2430	NA
Entry Point Samples			
Manganese, ppb	9.55	2.8 - 19.1	NA
Distribution Samples			
Bromochloroacetic Acid, ppb	1.98	0.45 - 3.9	NA
Bromodichloroacetic Acid, ppb	2.08	1.2 - 3.1	NA
Chlorodibromoacetic Acid, ppb	0.35	0 - 0.56	NA
Dibromoacetic Acid, ppb	0.14	0 - 0.94	NA
Dichloroacetic Acid, ppb	11.67	1.8 - 21.1	NA
Monobromoacetic Acid, ppb	0.06	0 - 0.72	NA
Monochloroacetic Acid, ppb	0.14	0 - 2.2	NA
Trichloroacetic Acid, ppb	15	9.1 - 26	NA

SPECIAL HEALTH INFORMATION:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons - such as persons with cancer and undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, as well as some elderly persons and infants - can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. The Environmental Protection Agency and Centers for Disease Control offer guidelines on the appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants. This information is available by calling the EPA's Safe Drinking Water Hotline at 800-426-4791.

SUBSTANCES EXPECTED TO BE IN DRINKING WATER:

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminant in bottled water which must provide the same protection for public health. Hazleton City Authority's water treatment processes are designed to reduce any such substances to levels well below any health concern and the processes are controlled to provide maximum protection against microbial and viral pathogens that could be naturally present in surface and groundwater. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminant does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. Environmental Protection Agency's Safe Drinking Water Hotline (800) 426-4791.

PROTECTING YOUR WATER SOURCE:

In 2018, the Hazleton City Authority completed comprehensive Source Water Protection Plans to protect their surface water intakes and groundwater wells. This project delineated protection zones for these water sources, identified potential sources of contamination, planned for potential pollution events, and selected management strategies that can be implemented in the future. This assessment found that our sources are potentially most susceptible to agricultural activities, roadways, and mining. Public education and watershed improvements are the primary focus of the program, which will benefit all residents and companies working and living in our service area. Hazleton City Authority encourages you to take an active part in protecting your water supply. More information is available by contacting HCA at 570-454-2401.

OTHER WATER QUALITY PARAMETERS OF INTEREST:

Lead Awareness: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hazleton City Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at <http://www.epa.gov/safewater/lead>.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home will be higher than at other homes in the community, as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested by a laboratory at your expense. Flush your tap for 30 seconds to two minutes before using tap water. Additional information is available from the **Safe Drinking Water Hotline at 800-426-4791**.

Water Hardness: Water hardness is a measure of the concentration of two minerals naturally present in water – calcium and magnesium. High hardness levels cause soap not to foam as easily as it would at lower levels. Hardness levels in the drinking water in the Hazleton Area are low, ranging from approximately 10 ppm to 35 ppm, or 0.5 to 2 grains per gallon of water.

Sodium levels: The sodium level in drinking water in the Hazleton System is low, approximately 16 ppm.

pH: Water in the Hazleton Distribution System averages approximately 7.1 pH units. A pH of 7.0 is neutral, neither acidic nor basic.

Fluoride: The Hazleton City Authority adds fluoride to your drinking water and maintains a level in the range recommended by the Pennsylvania Department of Environmental Protection (DEP).

DOES YOUR WATER CONTAIN NITRATES?

Hazleton City Authority's normal range of nitrates is well below the MCL of 10 ppm and was detected at a level of 0.26 ppm in the sample collected at the Hazleton Treatment Plant during 2019. Nitrate enters the water supply from fertilizers used on farms and natural erosion of deposits in the watershed. Levels above 10 ppm are a health risk for infants under six months of age and can cause blue baby syndrome. Check with your physician if you have questions.

HOW TO CONTACT US:

Addition copies of this report can be obtained by calling our Customer Service Department at 570-454-2401. Added information can be gathered by calling our Customer Service Department or by viewing the following information on the internet. HCA Website: hcawater.org

WATER INFORMATION SOURCES:

Pennsylvania Department of Environmental Protection - www.dep.state.pa.us

U.S. Environmental Protection Agency - www.epa.gov/safewater

Safe Drinking Water Hotline - (800) 426-4791

Center for Disease Control and Protection - www.cdc.gov

American Water Works Association - www.awwa.org

HAZLETON CITY AUTHORITY BOARD OF DIRECTORS

Michael DeCosmo Jr, Patrick Fay, John Keegan, John Nilles, Robert Stefanovich

SHARE THIS REPORT

Landlords, businesses, schools, hospitals and other groups are encouraged to share this important water quality information with water users at their location who are not billed customers of the Hazleton City Authority and therefore do not receive this report directly.